

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140922-E40857  
**Report Reference** E40857-19971015  
**Issue Date** 2014-SEPTEMBER-22

**Issued to:** UNITED ELECTRIC CONTROLS CO  
180 DEXTER AVE  
PO BOX 9143  
WATERTOWN MA 02472

**This is to certify that  
representative samples of**


Float- and Pressure-operated Motor Controllers for Use in Hazardous Locations  
12 Series Pressure-Operated Switch for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III hazardous locations. Cat. No. 12, followed by S or A, followed by L or H, followed by S or D, followed by N or M, followed by one character/digit alphanumeric code, followed by one character/digit alphanumeric code, followed by one or more four character/digit alphanumeric code or 12 followed by a five character/digit alphanumeric code.  
Enclosure Type 4X.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page  
**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and

"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140922-E40857  
**Report Reference** E40857-19971015  
**Issue Date** 2014-SEPTEMBER-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Standards for Safety:

UL 1203 4th Edition, "Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations"

UL 508, 17th Edition, "Industrial Control Equipment"

ANSI/ISA 12.27.01-2003, "Requirements for Process Sealing Between Electrical Systems and Flammable or Combustible Process Fluids"

C22.2 No. 14-M91, "Industrial Control Equipment"

C22.2 No. 25-1966, "Enclosures for Use in Class II, Groups E, F, and G Hazardous Locations"

C22.2 No. 30-1986, Canadian Electrical Code, Part I, "Explosion-Proof Enclosures for Use in Class I Hazardous Locations"



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

