

Dual Seal

UE Declaration of Conformity

Postal

180 Dexter Avenue
PO Box 9143
Watertown, MA
02472-9143
USA

Shipping

180 Dexter Avenue
Watertown, MA
02472-4200
USA

FAX

617-926-2568

Telephone

617-926-1000

Web Address

www.ueonline.com

Manufacturer's Name and Address:

United Electric Controls, Co.
180 Dexter Avenue
Watertown, MA 02472, U.S.A.

Type of Equipment:

Pressure Operated Switch

**Product Series:
Models:**

ONE Series
1XSWLL, 1XTXSW, 1XTX00, 2X2D,
2X4D, 2X3A, 2XLP,
2SLP, 4X3A, 8X2D

**Dual Seal
option code:**

M041

**Standards to which
Conformity is Declared:**

ANSI/ISA 12.27.01, UL 60079-0, UL 60079-1
UL 61010-1, UL 50, UL 50E and UL 1203
CSA C22.2 Nos. 25, 30, 60079-0, 60079-1,
61010-1,

Conformity Assessment:

cULus
UL file E226592.
Class I, Groups B, C, D Class II, Groups E, F, G,
Class III Hazardous Locations

Dual Seal Evaluation Per ANSI/ISA 12.27.01-2011

United Electric Control's ONE series was evaluated by UL in the file E226592 under ANSI/ISA 12.27.01 clause 6.3.3 for venting pressure determination and 6.3.5 for Secondary Leakage Test. UL found the ONE Series to be in compliance with the secondary seal requirements in ANSI/ISA 12.27.01.

Authorized Signature:



Name: Eric Moitoso
Title: Certification Engineer

12/15/2015

