


RIGHT HAND THREAD TURN IN FOR LOWER TEMPERATURE SETTING. MUST ALWAYS BE SET TO ACTUATE AT LOWER TEMPERATURE THAN RIGHT HAND SWITCH. RIGHT HAND SWITCH SET TO DIAL.



IMPORTANT NOTE:
 QUALITY CONTROL MUST INSPECT THE OPERATION OF CONTROLS AT THE LOW END OF THE RANGE FOR EACH BATCH MANUFACTURED, BESIDES THE STANDARD INSPECTION PERFORMED.

#6-32NC-2 HOLE 4 PLACES. (FOR PANEL MOUNTING)

| U | REDRAWN, NO CHANGE. | ECN#C6929 | 12-17-97 | P.W. | J.J.M. |
|-----|---------------------|-----------|----------|------|--------|
| SYM | DESCRIPTION | DATE | DWN | APPD | |
| | REVISIONS | | | | |

| | |
|--------------------------------|---------------|
| ORIGINAL DATE | 1-26-72 |
| DRWN | PETER WEILER |
| CHKD | A.J.MUSTO JR. |
| APPD | A.J.MUSTO JR. |
| UNLESS OTHERWISE SPECIFIED | |
| DIMENSIONS ARE IN INCHES | |
| TOLERANCES ON FRACTIONS ±1/64 | |
| 2 PLACE DEC 3 PLACE DEC ANGLES | |
| ±.010 | ±.005 ±1/2" |
| DO NOT SCALE THIS DRAWING | |

| | |
|-------|-------------------------------------|
| TITLE | E55AS E20 TO E23 (CALIBRATED) |
| SCALE | FULL |

| |
|---|
| DF001 REV. B |
| UE UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS |
| DWG NO A-11074 |