



UL LISTED, CSA CERTIFIED.
NEMA 4; 4X; IP65.

I & M SHEET IMP105

CHART 'A'		
126-164	6 9/16 [166.6mm]	1/4
S126B-S164B	7 [177.8mm]	1/2
MODEL NO	DIM 'A'	NPTF

CHART 'B'			
164	S164B	0 TO 200	0 TO 13.8
156	S156B	0 TO 100	0 TO 6.9
146	S146B	0 TO 30	0 TO 2.1
144	S144B	0 TO 20	0 TO 1379 mbar
137	S137B	2 TO 80" WC	5.0 TO 199.1 mbar
134	S134B	30" Hg Vac TO 20 psi	-1.0 bar TO 1379 mbar
126	S126B	30" Hg Vac TO 0 psi	-1.0 TO 0
MODEL NO.	psi		bar
	ADJUSTABLE RANGE		

SYM	DESCRIPTION	DATE	DVN	APPD
S	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
R	MODELS# 126-164 WERE ON DWG# 11861. ECN#C7277	5-8-98	S.R.	L.C.
P	UPDATED NOTES AND COMPONENTS ON COMP. BOM. ECN#C4026	12-14-94	A.E.	J.M.
N	REV. PLUNGER ON "M" DW'G. MODEL S134B ONLY. ECN#C3169	3-3-94	A.E.	J.M.
M	REV. PLUNGER ON MOD. S137B, S144B & S146B. ECN#C2854	12-20-93	A.E.	J.M.
L	UPDATED NOTES & COMPONENTS ON "M" DRAWING. ECN#C2573	8-19-93	A.E.	J.M.
K	RE-DRAWN NO CHANGE.	12-18-92	P.W.	A.M.

ORIGINAL DATE	9-18-78
TITLE	H105
DRWN	HELDER GARCIA
CHKD	A.J. MUSTO Jr.
APPD	A.J. MUSTO Jr.
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
DO NOT SCALE THIS DRAWING	

SCALE	HALF
-------	------

DF001D
UE UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS
DWG NO A-11860