



APPROVALS:
 CULUS LISTED
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
Ex II 2 G/D EE× d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP65

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)



I & M SHEET IMP120

274	6 to 300	0.4 to 20.7
270	4 to 200	0.3 to 13.8
MODEL NO.	psl	bar
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

SYM	DESCRIPTION	DATE	DWN	APPD
T	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
S	CHANGED kPa TO bar ECN#E0053	10/7/02	AB	HN
R	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
P	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
N	REVISED INSTRUCTION LABEL. ECN#C6557	7-31-97	P.W.	J.S.M.
M	REDRAWN PER REDESIGN. ECN#C5327	2-12-96	S.R.	JJM

ORIGINAL DATE	2-4-86
DRWN	P. WEILER
CHKD	A.J. FLECCA
APPD	A. MINASSIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
DO NOT SCALE THIS DRAWING	

TITLE	J120-270 & 274
SCALE	1:2

DF001 REV. B
UE
UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS
DWG NO A-12108