



**COVER REMOVED
IN FRONT VIEW**



APPROVALS:
 CLASS LISTED
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb, ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb, ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)

| | | |
|-------|---------------------------|---------------|
| 614 | 500 to 6000 | 34.5 to 413.7 |
| 612 | 200 to 3000 | 13.8 to 206.8 |
| MODEL | psi | bar |
| ND. | ADJUSTABLE RANGE | |
| | LOW END OF RANGE DN FALL | |
| | HIGH END OF RANGE DN RISE | |

| SYM | DESCRIPTION | DATE | DWN | APPD |
|-----|---|---------|------|------|
| P | UPDATED ENCLOSURE. ECN#E4345. | 2-17-12 | RCI | SJM |
| N | REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368 | 6-17-03 | S.R. | LK |
| M | CHANGED KPa TO bar. ECN#E0053 | 10/7/02 | AB | HN |
| L | ADDED CENELEC & CE APPROVALS. ECN#E0009 | 8-27-02 | S.R. | LK |
| K | UPDATED ENCLOSURE & COVER. ECN#C9734 | 2/27/02 | S.R. | LK |
| J | REDRAWN PER REDESIGN. ECN#C6050 | 12-6-96 | S.R. | JJM |

ORIGINAL DATE 7-29-86
 DRWN PETER WEILLER
 CHKD N.MACKAY JR.
 APPD A. MINASSIAN
 UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES

| | | |
|--|-----------|-------------------|
| TITLE | H121 | DF 001 |
| | 612 & 614 | REV. C |
| UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS | | DWG NO A-12122 |

REVISIONS
 DO NOT SCALE THIS DRAWING
 SCALE 1:2