



APPROVALS:
 cULus LISTED
 CLASS I, DIVISIONS 1 & 2, GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2, GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9



CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP66

CE COMPLIANT TO APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

RANGE: 100 to 1700 psi
 6.9 to 117.2 bar
 LOW END OF RANGE ON FALL
 HIGH END OF RANGE ON RISE

SYM	DESCRIPTION	DATE	DWN	APPD
W	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
V	CHANGED kPa TO bar ECN#E0053	10/7/02	AB	HN
U	ADDED CE APPROVAL. ADDED cULus & CENELEC SYMBOLS. ECN#E0009	8-27-02	S.R.	LK
T	UPDATED AG'CY. SPECS. ECN# C9996	8/8/02	PLW	GW
S	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
R	REDRAWN PER REDESIGN. ECN#C5327	2-12-96	S.R.	JJM
REVISIONS				

ORIGINAL DATE	2-4-86
DRWN	P. WEILER
CHKD	A.J. FLECCA
APPD	A. MINASSIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
DO NOT SCALE THIS DRAWING	

TITLE	J120-680
SCALE	1:2

DF001
REV. B

UNITED ELECTRIC
CONTROLS COMPANY
WATERTOWN * MASSACHUSETTS

DWG NO
A-12141