



COVER REMOVED
IN FRONT VIEW

SYM	DESCRIPTION	DATE	DWN	APPD
U	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
T	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
S	CHANGED kPa TO bar. ECN#E0053	10/7/02	AB	HN
R	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
P	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
N	REDRAWN PER REDESIGN. ECN#G6050	12-6-96	SR	JJM

REVISIONS	DESCRIPTION	DATE	DWN	APPD
U	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
T	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
S	CHANGED kPa TO bar. ECN#E0053	10/7/02	AB	HN
R	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
P	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
N	REDRAWN PER REDESIGN. ECN#G6050	12-6-96	SR	JJM

ORIGINAL DATE	DATE	DRWN	CHKD	APPD	TITLE
7-29-86	7-29-86	PETER WEILLER	N.MACKAY JR.	A.MINASSIAN	H122
					612 & 614

MODEL	PSI	LOW END OF RANGE	HIGH END OF RANGE	UNITED ELECTRIC CONTROLS COMPANY
614	500 to 6000	34.5 to 413.7		WATERTOWN * MASSACHUSETTS
612	200 to 3000	13.8 to 206.8		

APPROVALS:
 CULUS LISTED
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb, ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb, ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

SCALE 1:2

DWG NO
 A-12150

DF 001
 REV. C