



MAIN ADJUSTMENT:
R.H. THREAD TURN OUT FOR
HIGHER VACUUM SETTING.
(BOTH SWITCHES).

ADJUSTMENT (LOW SWITCH):
R.H. THREAD TURN OUT FOR
HIGHER VACUUM SETTING.

ORIGINAL DATE	6-30-81
DRWN	N.MackAY JR.
CHKD	A.J.MUSTO JR.
APPD	E.A.DesROSIUS
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS ±1/64 2 PLACE DEC 3 PLACE DEC ANGLES ±.010 ±.005 ±1/2"	
DO NOT SCALE THIS DRAWING	

TITLE	J54AS 22 (VACUUM)
SCALE	3/4:1

DF002
REV. A

UNITED ELECTRIC
CONTROLS COMPANY
WATERTOWN * MASSACHUSETTS

DWG NO
A-12166

H	DESCRIPTION	DATE	DWN	APPD
	REVISIONS			