



APPROVALS:

CULus LISTED
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9



I & M SHEET IMP120

RANGE: 10 TO 100 psi
 0.7 TO 6.9 bar
 LOW END OF RANGE ON FALL
 HIGH END OF RANGE ON RISE

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)

SYM	DESCRIPTION	DATE	DWN	APPD
S	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
R	CONVERTED kPa ADJUSTABLE RANGE TO bar. ECN#E0037	9-10-02	S.R.	LK
P	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
N	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
M	REDRAWN PER REDESIGN. ECN#C5959	10-29-96	S.R.	JJM
REVISIONS				

ORIGINAL DATE	9-18-86
DRWN	P. WEILER
CHKD	A.J. FLECCA
APPD	A. MINASSIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
DO NOT SCALE THIS DRAWING	

TITLE	J120K-367
SCALE	1:2

DF001 REV. B
UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS
DWG NO A-12458