



COVER REMOVED
IN FRONT VIEW

APPROVALS:
CLASS LISTED
CLASS I, DIVISIONS 1 & 2, UL US
GROUPS B, C & D
CLASS II, DIVISIONS 1 & 2,
GROUPS E, F & G
CLASS III
-50°C ≤ Tamb, ≤ +71°C
CLASS I, ZONE 1, GROUP IIB + H₂ T6
ENCLOSURE TYPE 4X, 7, 9
 0539 ATEX APPROVED
II 2 G/D EEx d IIC T6
-40°C ≤ Tamb, ≤ +71°C
IP66
CE COMPLIANT TO
APPLICABLE DIRECTIVES)
I & M SHEET IMP120

705	200 to 1000	13.8 to 68.9
704	50 to 500	3.4 to 34.5
703	30 to 300	2.1 to 20.7
702	10 to 100	0.7 to 6.9
MODEL NO.	psi	bar
ADJUSTABLE RANGE		
LOW END OF RANGE ON FALL		
HIGH END OF RANGE ON RISE		

Y	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
X	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
W	CHANGED kPa TO bar. ECN#E0053	10/7/02	AB	HN
V	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
U	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
T	REVISED PER REDESIGN. ECN#C5728	7-24-96	S.R.	JJM
SYM	REVISIONS	DATE	DWN	APPD

ORIGINAL DATE 7-29-86
DRAWN PETER WEILLER
CHKD N.MOCKAY JR.
APPD A.MINASSIAN
UNLESS OTHERWISE SPECIFIED
DIMENSIONS ARE IN INCHES

TITLE	H122
	702 - 705
SCALE	1:2
DWG NO	A-12465
UNITED ELECTRIC CONTROLS COMPANY	WATERTOWN * MASSACHUSETTS
DF 001	REV. C