

UL LISTED, CUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III, ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMT117.

121	200 TO 425	95 TO 215
120	0 TO 225	-15 TO 105
MODEL NO.	°F	°C
	ADJUSTABLE RANGE	


COVER REMOVED IN FRONT VIEW

SYM	DESCRIPTION	DATE	DWN	APPD
Z	DELETED ADJ. LOCK. ECN# E0004	9/6/02	PLW	LK.
Y	REVISED VIEW OF TERMINAL BLOCK & SPECS.. ECN#C8438	11-22-99	S.R.	VPD
X	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NENA 4X, 7, 9. ECN#C7775	12-3-98	P.W.	S.F.
W	REDRAWN ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6848	10-31-97	P.W.	A.M.

ORIGINAL DATE	6-17-87
DRWN	A. EBALD
CHKD	A.J.FLECCA
APPD	L.KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS 1/64	
2 PLACE DEC 3 PLACE DEC ANGLES ± .010 ± .005 ± 1/2°	
DO NOT SCALE THIS DRAWING	

TITLE	B117
SCALE	HALF

DF1



UNITED ELECTRIC
 CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO
 A-12753