



UL LISTED, cUL CERTIFIED.
 CLASS I DIVISION 2, GROUPS A, B, C, D.
 CLASS II DIVISION 2, GROUP F, G.
 CLASS III. ENCLOSURE TYPE 4X
 CLASS I, ZONE 2, GROUP IIC T6

I & M SHEET IMP117.

376	25 TO 500	1.7 TO 34.5
361	20 TO 300	1.4 TO 20.7
358	15 TO 200	1.0 TO 13.8
MODEL NO.	psi	bar
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

COVER REMOVED IN FRONT VIEW

X	CHANGED kPa TO bar. ECN#E0047	10-23-02	S.R.	H.N.
W	REVISED VIEW OF TERMINAL BLOCK & SPECS. ECN#C0430	11-22-99	S.R.	VPD
V	CERTIFICATION WAS CSA. REQUIREMENT NOTE WAS NEMA 4X, 7, 9. ECN#C7775	12-3-98	P.V.	S.F.
U	ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6040	10-31-97	P.V.	A.M.
T	CLASS III WAS NEMA 4, 4X, 9, IP65. REVISED ENCLOSURE & COVER ON "M" DW'G. ECN#C5109	1-16-96	P.V.	J.S.M.
S	REVISED TO CAPTIVE COVER SCREW. ECN#C5019	11-30-95	P.V.	J.S.M.
R	DELETED ISSEP CERTIFIED & GROUPS E & F FROM SPECS. REV. BELLOWS HS'G ADAPTOR ON "M" DWG. ECN#G4162	12-22-94	AE.	J.S.M.
Q	REDRAWN & UPDATED PER ECN#C2571	10-1-93	P.W.	A.M.
SYM	DESCRIPTION	DATE	DVN	APPD
REVISIONS				

ORIGINAL DATE	8-19-88
DRWN	A. EBALD
CHKD	PETER WEILER
APPD	A. MINASSIAN

TITLE	H117
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
SCALE	HALF

DF001D
UE
UNITED ELECTRIC CONTROLS COMPANY
WATERTOWN * MASSACHUSETTS
DWG NO
A-12758