



UL LISTED, CSA CERTIFIED.
 CONFORMS TO NEMA 4X & IP65
 REQUIREMENTS.
 I & M SHEET IMP100.

174	8 TO 200	0.6 TO 13.8
173	4 TO 100	0.3 TO 6.9
172	2 TO 50	0.1 TO 3.4
171	1 TO 20	68.9 TO 1379 mbar
MODEL NO.	psi	bar
	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

SYM	DESCRIPTION	DATE	DVN	APPD
H	CHANGED kPa TO bar. ECN#E0046	10-23-02	S.R.	H.N.
G	REMOVED MODEL 175. ECN# C9187.	4/2/01	PLW	L.K.
F	REVISED kPa ADJ. RANGES. ADDED MODEL 175. ECN#C8460	1-20-00	S.R.	L.K.
E	DELETED MODELS 471-474 DC#25636	5/7/99	AB	AB
D	ADDED 1" (25.4mm) & 5/16 (7.94mm) DIMENSIONS. ECN#C6848	10-31-97	P.V.	AM.
C	REV. COVER SCREW AND ADDED "D" RING ON "M" DVG. ECN#C4972	11-10-95	P.V.	J.S.M.
BI	REVISED & UPDATED PER ECN#C2515	7-27-93	P.V.	AM.
B	ADDED MODELS 471 THRU 474 TO CHART ECN#C1566CN#	10-1-92	P.V.	G.F.Y.
AI	FIRST ISSUE. ECN#7803	9-29-90	P.W.	G.F.Y.

ORIGINAL DATE	2-19-91
DRWN	PETER WEILER
CHKD	PETER WEILER
APPD	G. YUSKAUSKAS

TITLE	H100
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	
SCALE	HALF

DF001D
UNITED ELECTRIC CONTROLS COMPANY
WATERTOWN * MASSACHUSETTS
DVG NO
A-12837