



**COVER REMOVED
IN FRONT VIEW**

APPROVALS:
 CE LISTED
 CLASS I, DIVISIONS 1 & 2, cUL US
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb, ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + Ha T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb, ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVES)

I & M SHEET IMP120

SYM	DESCRIPTION	DATE	DWN	APPD
H	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
G	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
F	CHANGED KPa TO bar. ECN#E0053	10/7/02	AB	HN
E	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
D	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
C	REDRAWN PER REDESIGN. ECN#G6130	1-7-97	S.R.	JJM

SYM	DESCRIPTION	DATE	DWN	APPD
H	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
G	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
F	CHANGED KPa TO bar. ECN#E0053	10/7/02	AB	HN
E	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
D	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
C	REDRAWN PER REDESIGN. ECN#G6130	1-7-97	S.R.	JJM

REV	DESCRIPTION	DATE	DWN	APPD	SCALE
1	ORIGINAL DATE 9-6-94	9-6-94			1:2
2	DRWN PETER WEILLER				
3	CHKD P. WEILLER				
4	APPD A. MINASSIAN				

MODEL	ADJUSTABLE RANGE	LOW END OF RANGE ON FALL	HIGH END OF RANGE ON RISE
274	0 to 300 psi	0 to 20.7 bar	
270	0 to 200 psi	0 to 13.8 bar	

UNITED ELECTRIC CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS

DWG NO: A-12953

REV. C

DF001