



COVER REMOVED  
IN FRONT VIEW

APPROVALS:  
CLASS I, DIVISIONS 1 & 2,  
GROUPS B, C & D  
CLASS II, DIVISIONS 1 & 2,  
GROUPS E, F & G  
CLASS III  
-50°C ≤ Tamb. ≤ +71°C  
CLASS I, ZONE 1, GROUP IIB + H<sub>2</sub> T6  
ENCLOSURE TYPE 4X, 7, 9

**UL** US

CE 0539 ATEX APPROVED  
II 2 G/D EEx d IIC T6  
-40°C ≤ Tamb. ≤ +71°C  
IP66

CE COMPLIANT TO  
APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

614	500 to 6000	34.5 to 413.7
612	200 to 3000	13.8 to 206.8
MODEL	psi	bar
ND.	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

H	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM	ORIGINAL DATE	9-6-94	TITLE	H122P-	DF 001
G	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK	DRWN	PETER WEILLER	612 & 614	REV. C	UNITED ELECTRIC
F	CHANGED I.P.A. TO bar. ECN#E0053	10/7/02	AB	HN	CHKD	P. WEILLER			CONTROL'S COMPANY
E	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK	APPD	A. MINASSIAN			WATERTOWN * MASSACHUSETTS
D	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK					
C	REDRAWN PER REDESIGN. ECN#G6180	2-4-97	SR	JJM					
SYM	DESCRIPTION	DATE	DWN	APPD	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES				
REVISIONS					DO NOT SCALE THIS DRAWING				
					SCALE 1:2				
					DWG NO A-12955				