



COVER REMOVED
IN FRONT VIEW

APPROVALS: **cULus**
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb, ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb, ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVES

CHART 'B'	
454	0 to 30
453	0 to 20
452	30"HgVac to 20 psi
450	30"HgVac to 0 psi

ADJUSTABLE RANGE	
LOW END OF RANGE ON FALL	bar
HIGH END OF RANGE ON RISE	bar

SYMBOL	DESCRIPTION	DATE	DW	APPD	ORIGINAL DATE	TITLE	DWG NO
H	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM	9-6-94	H122P-450	A-12956
G	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK	9-6-94	H122P-450	A-12956
F	CHANGED KPa TO bar. ECN#E0053	10/27/02	AB	HN	9-6-94	H122P-450	A-12956
E	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK	9-6-94	H122P-450	A-12956
D	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK	9-6-94	H122P-450	A-12956
C	REVISED PER REDESIGN. ECN#C6167	1-21-97	S.R.	JJM	9-6-94	H122P-450	A-12956

UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES

UNITED ELECTRIC
 CONTROL COMPANY
 WATERTOWN * MASSACHUSETTS

DF 001
 REV. C
 8 15/16 [227mm]
 9 11/16 [246.1mm]
 DIM 'A'