



APPROVALS:
 cULus LISTED
 CLASS I, DIVISIONS 1 & 2, GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2, GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9



CE 0539 ATEX APPROVED
 Ex II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP66

CE COMPLIANT TO APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

SYM	DESCRIPTION	DATE	DWN	APPD
H	DEL. VENT HOLE NOTE. ECN#E1269	6-23-05	S.R.	LK
G	REPLACED GENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
F	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
E	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
D	REVISED INSTRUCTION LABEL. ECN#C6557	7-31-97	P.W.	J.S.M.
C	ADDED UL & CSA APPROVALS. ECN#C6587	6-26-97	P.W.	M.T.
B	REDRAWN PER REDESIGN. ECN#C5718	7-12-96	S.R.	JJM

REVISIONS

ORIGINAL DATE	3-8-95
DRWN	A. EBALD
CHKD	P. WEILER
APPD	L. KHATCHADDURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

DO NOT SCALE THIS DRAWING

564	8 TO 200	0.56 TO 13.79
563	4 TO 100	0.28 TO 6.90
562	2 TO 50	0.14 TO 3.45
561	1 TO 25	0.07 TO 1.72
560	0.5 TO 15	0.04 TO 1.03
MODEL NO.	psi	bar
	ADJUSTABLE RANGE	
LOW END OF RANGE ON FALL		
HIGH END OF RANGE ON RISE		

TITLE
 J120
 560-564
 SCALE 1:2

DF001
 REV. B

 UNITED ELECTRIC CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS
 DWG NO
 A-12987