



APPROVALS:

cULus LISTED
CLASS I, DIVISIONS 1 & 2, GROUPS B, C & D
CLASS II, DIVISIONS 1 & 2, GROUPS E, F & G
CLASS III
-50°C ≤ Tamb. ≤ +71°C
CLASS I, ZONE 1, GROUP IIB + H₂ T6
ENCLOSURE TYPE 4X, 7, 9



CE 0539 ATEX APPROVED
II 2 G/D EEx d IIC T6
-40°C ≤ Tamb. ≤ +71°C
IP66

CE COMPLIANT TO APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

SYM	DESCRIPTION	DATE	DWN	APPD
H	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
G	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
F	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
E	1-1/2" TRI-CLAMP STYLE WAS 2" ECN#C7283	5-12-98	P.W.	L.K.
D	REVISED INSTRUCTION LABEL. ECN#C6557	7-31-97	P.W.	J.S.M.
C	ADDED UL & CSA APPROVALS. ECN#C6587	6-26-97	P.W.	M.T.
B	REDRAWN PER REDESIGN. ECN#C5718	7-12-96	S.R.	JJM

ORIGINAL DATE	3-8-95
DRWN	A. EBALD
CHKD	P. WEILER
APP'D.	KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

567	15 TO 300	1.03 TO 20.68
566	10 TO 100	0.69 TO 6.90
565	5 TO 30	0.34 TO 2.07
MODEL NO.	psi	bar
ADJUSTABLE RANGE		
LOW END OF RANGE ON FALL		
HIGH END OF RANGE ON RISE		

TITLE
J120
565-567



DF001
REV. B
UNITED ELECTRIC
CONTROLS COMPANY
WATERTOWN * MASSACHUSETTS

DWG NO
A-12988

DO NOT SCALE THIS DRAWING

SCALE 1:2

REVISIONS