


OPTION NO.	DESCRIPTION OF OPTION: BT (BELOW the THREAD)
W075	BRASS 1/2 NPT with 3/4 NPT BUSHING x 4" BT
W076	316 st/st 3/4 NPT x 4.5" BT
W118	BRASS 1/2 NPT with 3/4 NPT BUSHING x 7" BT
W119	316 st/st 3/4 NPT x 7.5" BT
W177	316 st/st 1/2 NPT x 7.5" BT
W191	BRASS 1/2 NPT x 4" BT
W192	BRASS 1/2 NPT x 7" BT
W193	316 st/st 1/2 NPT x 4.5" BT

OFFERED ON TEMPERATURE PRODUCTS  
(REMOTE THERMAL ASSEMBLY):

54	119
55	120
100	400
105	650
117	800



**NOTE:**

- 4" - 4.5" BT WELLS FIT 3/8" O.D. BULBS UP TO 4" LONG.  
7" - 7.5" BT WELLS FIT 3/8" O.D. BULBS UP TO 7" LONG.

SYM	DESCRIPTION	DATE	DWN	APPD
C	1/2 NPT (BRASS) 1/2 OR 3/4 NPT(st/st) WAS 1/2 OR 3/4 NPT. ADDED (NEEDED FOR BRASS ONLY) & 3/4 NPT TO BUSHING ADAPTER. ECN# C8459	12/3/99	PLW	VPD
B	316 st/st WAS 304. ADDED 1-1/8 HEX. 0.75 DIA. WAS 0.50. ECN# C8247	7/27/99	PLW	V.P.
A	FIRST ISSUE. ECN# C6891	11/5/97	PLW	V.P.

REVISIONS

ORIGINAL DATE	11/5/97
DRWN	PLW
CHKD	V.P.
APPD	V.P.
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ON FRACTIONS ±1/64 2 PLACE DEC 3 PLACE DEC ANGLES ±0.01 ±0.05 ±1/2"	
DO NOT SCALE THIS DRAWING	

TITLE	REMOTE WELLS
USED ON:	
SCALE	NONE

DF003 REV. A
<b>UE</b> UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS
DWG NO A-62168-999-2