

CERTIFICATE OF COMPLIANCE

Certificate Number 20140710-E226592
Report Reference E226592-20090305
Issue Date 2014-July-10

Issued to: UNITED ELECTRIC CONTROLS CO
180 DEXTER AVE
PO BOX 9143
WATERTOWN MA 02472


**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS
BRAZILIAN CERTIFICATION SERVICES -
MISCELLANEOUS EQUIPMENT AND ACCESSORIES
FOR USE IN HAZARDOUS LOCATIONS
PROCESS CONTROL EQUIPMENT FOR USE IN ZONE
CLASSIFIED HAZARDOUSLOCATIONS
See Addendum Page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See addendum page for Standards.
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140710-E226592
Report Reference E226592-20090305
Issue Date 2014-July-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL One Series Electronic Pressure and Temperature Switch for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; Class III; Class I, Zone 1, AEx d IIC; Class I, Zone 1, Ex d IIC Hazardous Locations;

Model Nos. 2X2D, 2X3A, 2X4D, 2XLP, 4X3A or 8X2D; followed by 0 or 4; followed by N, 0, 1, 2, 3, 4 or 5; followed by P, T, or K; followed by 10-20 or L1, L2, L3, R1, RC, H1, HC, C1, CC, TC, or Ux; may be followed by one or more four character/digit alphanumeric code; or 2X,4X or 8X followed by a five character/digit alphanumeric Customer Specification code.

Model Nos. 2SLP, followed by 4; followed by 7, P, T, or K; followed by 06, 08, 10-20, L1, L2, L3, R1, RC, H1, HC, C1, CC, or TC or five character alphanumeric customer specification code.

USL, CNL One Series Electronic Pressure and Temperature Switch for use in Class I, Groups B, C, and D; Class II, Groups E, F, and G; Class III; Class I, Zone 1, AEx d IIC; Class I, Zone 1, Ex d IIC Hazardous Locations;

Model Nos. 2X2D, 2X3A, 2X4D, 2XLP, 4X3A or 8X2D; followed by 0 or 4; followed by N, 0, 1, 2, 3, 4 or 5; followed by P, T, or K; followed by 10-20 or L1, L2, L3, R1, RC, H1, HC, C1, CC, TC, or Ux; may be followed by one or more four character/digit alphanumeric code; or 2X,4X or 8X followed by M-041 or a five character/digit alphanumeric Customer Specification code.

Model Nos. 2SLP, followed by 4; followed by 7, P, T, or K; followed by 06, 08, 10-20, L1, L2, L3, R1, RC, H1, HC, C1, CC, or TC, M-041 or five character alphanumeric customer specification code.
Standards-



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20140710-E226592
Report Reference E226592-20090305
Issue Date 2014-July-10

Standard No. UL 50, Enclosures for Electrical Equipment, Non-Environmental Considerations
Standard No. UL 50E, Enclosures for Electrical Equipment, Environmental Consideration
Standard No. UL 61010-1, Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements
Standard No. UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
Standard No. CAN/CSA C22.2 No. 25-1966, Enclosures for Use in Class II, Groups E, F, and G Hazardous Locations
Standard No. CAN/CSA C22.2 No. 30-M1986, Explosion-Proof Enclosures for Use in Class I Hazardous Locations
Standard No. CAN/CSA C22.2 No. 61010-1, Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements
Standard No. UL 60079-0, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements
Standard No. UL 60079-1, Electrical Apparatus for Explosive Gas Atmospheres - Part 1: Flameproof Enclosures "d"
Standard No. CAN/CSA C22.2 No. 60079-0:11, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements
Standard No. CAN/CSA C22.2 No 60079-1:11, Electrical Apparatus for Explosive Gas Atmospheres - Part 1: Flameproof Enclosures "d"



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

