



APPROVALS:
 CULUS LISTED
 CLASS I, DIVISIONS 1 & 2,
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP65

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)



I & M SHEET IMP120

| | | |
|-----------|---------------------------|-------------|
| 376 | 25 to 500 | 1.7 to 34.5 |
| 361 | 20 to 300 | 1.4 to 20.7 |
| 358 | 15 to 200 | 1.0 to 13.8 |
| 356 | 15 to 100 | 1.0 to 6.9 |
| MODEL NO. | psi | bar |
| | ADJUSTABLE RANGE | |
| | LOW END OF RANGE ON FALL | |
| | HIGH END OF RANGE ON RISE | |

| SYM | DESCRIPTION | DATE | DWN | APPD |
|-----|---|---------|------|--------|
| Y | REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368 | 6-17-03 | S.R. | LK |
| X | CHANGED kPa TO bar ECN#E0053 | 10/7/02 | AB | HN |
| W | ADDED CE APPROVAL. ADDED CULUS & CENELEC SYMBOLS. ECN#E0009 | 8-27-02 | S.R. | LK |
| V | UPDATED AG'CY. SPECS. ECN# C9996 | 8/8/02 | PLW | GW |
| U | UPDATED ENCLOSURE & COVER. ECN#C9734 | 2/27/02 | S.R. | LK |
| T | REVISED INSTRUCTION LABEL. ECN#C6557 | 7-31-97 | P.W. | J.S.M. |
| S | REDRAWN PER REDESIGN. ECN#C5327 | 2-12-96 | S.R. | JJM |

| | |
|--|--------------|
| ORIGINAL DATE | 2-4-86 |
| DRWN | P. WEILER |
| CHKD | A.J. FLECCA |
| APPD | A. MINASSIAN |
| UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES | |
| DO NOT SCALE THIS DRAWING | |

| | |
|-------|---------------------------------|
| TITLE | J120- 356, 358, 361 & 376 |
| SCALE | 1:2 |

| |
|---|
| DF001 REV. B |
| UE UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS |
| DWG NO A-12109 |