



**COVER REMOVED
IN FRONT VIEW**

APPROVALS:
 CE LISTED
 CLASS I, DIVISIONS 1 & 2,  US
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb, ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + Ha T6
 ENCLOSURE TYPE 4X, 7, 9
 0539 ATEX APPROVED
 II 2 G/D EEX d IIC T6
 -40°C ≤ Tamb, ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVES)

I & M SHEET IMP120

376	0 to 500	0 to 34.5
361	0 to 300	0 to 20.7
358	0 to 200	0 to 13.8
MODEL	psi	bar
ND.	ADJUSTABLE RANGE	
	LOW END OF RANGE ON FALL	
	HIGH END OF RANGE ON RISE	

H	UPDATED ENCLOSURE. ECN#E4345.	2-17-12	RCI	SJM
G	REPLACED GENIELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
F	CHANGED KPa TO bar. ECN#E0053	10/7/02	AB	HN
E	ADDED GENIELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
D	UPDATED ENCLOSURE & COVER. ECN#C9734	3-26-02	S.R.	LK
C	REDRAWN PER REDESIGN. ECN#G6180	2-4-97	S.R.	JJM
SYM	DESCRIPTION	DATE	DWN	APPD

ORIGINAL DATE 9-6-94
 DRWN PETER WEILER
 CHKD P. WEILER
 APPD A. MINASSIAN
 UNLESS OTHERWISE SPECIFIED
 DIMENSIONS ARE IN INCHES

TITLE	H122P-358, 361 & 376
SCALE	1:2
DWG NO	A-12954
REV. C	UNITED ELECTRIC CONTROLS COMPANY WATERTOWN * MASSACHUSETTS
DF001	