



APPROVALS:
 cULus LISTED
 CLASS I, DIVISIONS 1 & 2, cULus
 GROUPS B, C & D
 CLASS II, DIVISIONS 1 & 2,
 GROUPS E, F & G
 CLASS III
 -50°C ≤ Tamb. ≤ +71°C
 CLASS I, ZONE 1, GROUP IIB + H₂ T6
 ENCLOSURE TYPE 4X, 7, 9

CE 0539 ATEX APPROVED
 II 2 G/D EEx d IIC T6
 -40°C ≤ Tamb. ≤ +71°C
 IP66

CE COMPLIANT TO
 APPLICABLE DIRECTIVE(S)

I & M SHEET IMP120

SYM	DESCRIPTION	DATE	DWN	APPD
H	RELOCATED VENT HOLE NOTE. ECN#E1269	6-23-05	S.R.	LK
G	REPLACED CENELEC APPROVAL WITH ATEX APPROVAL. ECN#E0368	6-17-03	S.R.	LK
F	ADDED CENELEC & CE APPROVALS. ECN#E0009	8-27-02	S.R.	LK
E	UPDATED ENCLOSURE & COVER. ECN#C9734	2/27/02	S.R.	LK
D	REVISED INSTRUCTION LABEL. ECN#C6557	7-31-97	P.W.	J.S.M.
C	REDRAWN PER REDESIGN. ECN#C5823	9-10-96	S.R.	JJM

REVISIONS

ORIGINAL DATE	3-10-94
DRWN	A. EBALD
CHKD	P. WEILER
APPD	L. KHATCHADOURIAN
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES	

535	10 TO 250	24,91 TO 622,70
534	2.5 TO 50	6,23 TO 124,54
533	0.5 TO 5	1,25 TO 12,45
532	-50 TO 50	-124,54 TO 124,54
531	-10 TO 10	-24,91 TO 24,91
530	-300 TO 0	-747,24 TO 0
MODEL	'wc	mbar
NO.	ADJUSTABLE RANGE	
LOW END OF RANGE ON FALL HIGH END OF RANGE ON RISE		

TITLE
 J120
 530 TO 535
 SCALE 1:2

DF001
 REV. B
UE
 UNITED ELECTRIC
 CONTROLS COMPANY
 WATERTOWN * MASSACHUSETTS
 DWG NO
 A-12962

DO NOT SCALE THIS DRAWING