


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON



PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR


| | |
|--|--|
| MANUFACTURERS NAME: <u>United Electric Controls</u> | |
| MANUFACTURERS ADDRESS: <u>180 Dexter Avenue, Watertown, MA 02472, United States</u> | |
| PLANT LOCATIONS: <u>180 Dexter Avenue, Watertown, MA 02472, United States</u> | |
| CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY | |
| <input type="radio"/> A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers <input type="radio"/> B Flanges: all flanges <input type="radio"/> C Valves: all line valves <input type="radio"/> D Expansion joints, flexible connections, and hose assemblies: all types <input type="radio"/> E Strainers, filters, separators, and steam traps <input checked="" type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters <input type="radio"/> G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs <input type="radio"/> H Pressure retaining components that do not fall into one of the above categories <input type="radio"/> N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> (Meeting CNSC or ASME requirements) | TITLE OF THE STANDARD OF CONSTRUCTION <u>ASME B31.3, 2022 Edition</u> |
| SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT  | TYPE OF CONSTRUCTION FORGED <input type="checkbox"/> WELDED <input type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER |
| LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: <u>Category F, Pressure Switches</u> <u>Scope Document: 6706s-1</u> | |

DECLARATION:

I, Charles Heines (see note 3) employed by United Electric Controls and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by SGS North America, Inc. as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: 
 Declared before me at Watertown
 This 17th day of May AD 2024
 Commissioner of Oaths or Notary Public: (sign) 

USE THIS SLIP A TERESA C. POLLMAN
 OF Notary Public
 Commonwealth of Massachusetts
 My Commission Expires
 September 20, 2024

| | |
|---|---|
| This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance Newfoundland Labrador | |
| CRN: <u>0F12361.2 Rev1</u> | Registered <u>0F12361.20 Rev1</u> |
| FID#: <u>961</u> | Date <u>Oct 16, 2024</u> |
| Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years. | Engineering and Inspection Services Registered by <u></u> UNDER THE AUTHORITY OF THE PUBLIC SAFETY ACT AND THE BOILER, PRESSURE VESSEL AND COMPRESSED GAS REGULATIONS Sect. 1.0 - Fittings Rev. 1 06/2003 |

Postal

180 Dexter Avenue
Watertown, MA
02472-4200
USA

Select UE pressure and differential pressure models have been issued a Canadian Registration Number (CRN) for use in Canada. CRN certificates for all Canadian provinces and territories are available on the UE website (<https://www.ueonline.com/crn-ca/>).

Telephone

617-926-1000

A summary of CRN registered pressure and differential pressure models and those with restrictions follows:

Web Address

www.ueonline.com

Series and models with CRN registration^[6]

| <u>Series</u> | <u>Model Numbers</u> |
|---|--|
| J6 Series | 354, 356, 358, 360, 362, 364, 610, 612, 614, 680 |
| 10 Series | 10 – 16, 15803 |
| 12 Series^{[1][2]} | 2 – 9, P0 – P9 |
| J21K Series | 357 |
| 100/117 Series^[3] | 171 – 174, 183 – 194, 483 – 486, 488 – 494, 358, 361, 376, 610, 612, 616, 680, 701 – 706 |
| 120 Series^[4] | 171 – 174, 183 – 194, 483 – 486, 488 – 494, 356, 358, 361, 376, 552 – 555, 610, 612, 616, 680, 701 – 706 |
| 400 Series | 358, 361, 376, 552 – 555, 570 – 572, 610, 612, 614 |
| One Series/Excelsa^[5] | P10 – P20, K10 – K13 |



Product models with Maximum Service Pressure restrictions for CRN registration

- [1] 12 Series Models P4 and P9 are derated from 12,500 psi to 9,900 psi.
- [2] 12 Series Models 3 and 5 with standard ½" NPTM pressure connection are derated from 6,000 psi to 3,350 psi unless option M511 is chosen.
- [3] 100/117 Series Models 189 and 489 are derated from 3,500 psi to 3,350 psi.
- [4] 120 Series Models 189 and 489 are derated from 3,500 psi to 3,350 psi.
- [5] One Series and Excelsior gage pressure sensors are derated from 6,000 psi to 4,450 psi.

Process connection material restrictions for CRN registration

[6] Canadian Registration Numbers (CRN) are valid for products with process connections constructed from Stainless Steel Type 316 (ASTM 479) material only. Some products have standard Stainless Steel Type 316 process connection materials. Some products will require an option (i.e. M511, M540, etc.) to change the process connection material to Stainless Steel Type 316 to be CRN compliant. Please consult UE website and product datasheets for standard and optional process connection materials when selecting product models.

For any questions and further CRN registration information (62174-63 Calculations, 6706s-1 Scope, etc.) please contact UE Sales Application Engineering at InsideSales@ueonline.com.