

CERTIFICATE OF COMPLIANCE

Certificate Number E43374
Report Reference E43374-19980702
Issue Date 2023-September-15

Issued to: UNITED ELECTRIC CONTROLS CO
180 DEXTER AVE
PO BOX 9143
WATERTOWN MA 02472

This is to certify that representative samples of TEMPERATURE-INDICATING AND -REGULATING EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS
See Addendum for Additional Information.


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203, 5th Edition, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.
UL 873, C22.2 No. 24-M91 Temperature-Indicating and -Regulating Equipment
CAN/CSA C22.2 No. 25-1966 (R2014), Enclosures for Use in Class II Groups E, F, and G Hazardous Locations.
CAN/CSA C22.2 No. 30-M1986 (R2016) Explosion-Proof Enclosures for Use in Class I Hazardous Locations.
Canadian Electrical Code, Part I.

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E43374
Report Reference E43374-19980702
Issue Date 2023-September-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum –

Products Covered:

12 Series Temperature Switch for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III Hazardous Locations. Cat. No. 12, followed by S or A, followed by L or H, followed by S or D, followed by N or M, followed by one character/digit alphanumeric code, followed by one character/digit alphanumeric code, followed by one or more four character/digit alphanumeric code, or 12 followed by a five character/digit alphanumeric code. Enclosure Type 4X.

Ambient Temperature Range, -50°C (-58°F) to 95°C (203°F).



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

