


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: United Electric Controls	
MANUFACTURERS ADDRESS: 180 Dexter Avenue, Watertown, MA 02472, USA	
PLANT LOCATIONS: <u>AS ABOVE</u>	
CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> . (Meeting CNSC or ASME requirements)	TITLE OF THE STANDARD OF CONSTRUCTION ASME B31.3 2012 EDITION
SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT 	TYPE OF CONSTRUCTION FORGED <input checked="" type="checkbox"/> WELDED <input checked="" type="checkbox"/> WROUGHT <input type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:
LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED: DRAWINGS: Refer to PVEscp-6706.0 CALCULATIONS: PVEcl-6706-0.0 BURST REPORT: 13010913 Pressure, Vacuum, Differential and Temperature switches/sensors.	

DECLARATION:

I, Eric Maitoso (see note 3) employed by United Electric Controls and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV Business Assurance as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Eric Maitoso
 Declared before me at Watertown, Massachusetts
 This 9th day of September AD 2013
 Commissioner of Oaths or Notary Public: (sign) [Signature]

USE THIS NEW SERVICE
BRUNSWICK
 DEPT OF PUBLIC SAFETY
 BOILER & PRESSURE VESSEL ACT



This space for Regulatory Authority use This registration must be revalidated after ten (10) years from the date of acceptance.	
CRN: <u>0F16515.5</u> FID#: <u>961</u>	REGISTRATION ONLY CRN <u>0F16515.57</u> EXAMINER: <u>[Signature]</u> for CHIEF BOILER INSPECTOR DATE: <u>01/17/2014</u> <input type="checkbox"/> BLRs <input type="checkbox"/> FVs <input type="checkbox"/> FITTINGS <input type="checkbox"/> COMPONENTS
Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.	



345 Carlingview Drive
Toronto, Ontario
CANADA M9W 6N9
Tel.: 416.734.3300
Fax.: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

March 29, 2018

SCOTT KAYHART
UNITED ELECTRIC CONTROLS
180 DEXTER AVE
WATERTOWN MA 02472
US

Service Request Type.: BPV-National ACI Central
Service Request No.: 2230776
Your Reference No.:
Registered to.: UNITED ELECTRIC CONTROLS

Dear SCOTT KAYHART,

Please find enclosed the original response from PEI,NS,NB,NFLD,YK,NWT,NU, registered under the CRN No.: 0F16515.59870YTNADD1.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you. For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Tanya Francis
Administrative Assistant_ BPV Engineering
Tel. : 416-734-3423
Fax : 416-231-6183
Email : tfrancis@tssa.org


UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS

NEW BRUNSWICK
NUNAVUT

NOVA SCOTIA
YUKON

PRINCE EDWARD ISLAND
NORTHWEST TERRITORIES



NEWFOUNDLAND AND LABRADOR

MANUFACTURERS NAME: <u>United Electric Controls</u>	
MANUFACTURERS ADDRESS: <u>180 Dexter Avenue, Watertown, MA 02472 USA</u>	
PLANT LOCATIONS: <u>Same as above</u>	
<p align="center">CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers B Flanges: all flanges C Valves: all line valves D Expansion joints, flexible connections, and hose assemblies: all types E Strainers, filters, separators, and steam traps <input checked="" type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs H Pressure retaining components that do not fall into one of the above categories N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting AECB or ASME requirements)</p>	<p align="center">TITLE OF THE STANDARD OF CONSTRUCTION</p> <p align="center">ASME B31.3</p>
<p>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</p> <div style="text-align: center;">  </div>	<p align="center">TYPE OF CONSTRUCTION</p> <p>FORGED <input type="checkbox"/> WELDED <input checked="" type="checkbox"/> WRUGHT <input checked="" type="checkbox"/> CAST <input type="checkbox"/> OTHER <input type="checkbox"/> DESCRIBE OTHER:</p>
<p>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</p> <p>Drawings: Refer to PVEscp-6706.1 Calculations: PVEclc-6706-0.0 Burst Report: 13010913</p>	

DECLARATION:

I Brenda Ripley (see note 3) employed by United Electric Controls and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV GL for ISO 9001:2015 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Brenda Ripley
 Declared before me at 180 Dexter Ave, Watertown, MA 02472
 This 3rd day of January AD 2018
 Commissioner of Oaths or Notary Public: (sign) [Signature]
 (Affix Official seal to the right)



<p align="center">This space for Regulatory Authority use</p> <p align="center">This registration must be revalidated after ten (10) years from the date of acceptance.</p> <p>CRN: <u>OF16515.5 ADD1</u></p> <p>FID#: <u>961</u></p> <p>Notes: 1. All fittings shall be registered in the name of the Manufacturer. 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation. 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product. 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.</p>	<p>New Brunswick DEPT OF PUBLIC SAFETY BOILER & PRESSURE VESSEL ACT</p> <p align="center">REGISTRATION ONLY</p> <p>CRN <u>OF16515.57Add1</u></p> <p>EXAMINER: <u>[Signature]</u> for CHIEF BOILER INSPECTOR</p>
--	---

DATE: 2/9/2018

BLRs PVs
 FITTINGS COMPONENTS



File Name: PVEscp-6706.1
Document Name: Scope of Work
PVE Project: PVE-6706
Revision: 1
PVE Contact: Patrick Fernandes
United Electric Contact: Eric Moitoso

05-Dec-17

Registration Information					Burst Test Results			CRN Info			
Burst Sample No.	Burst Test Series-Model	Applicable Models	Drawing No.	Dwg Rev.	Compatible Series Numbers	Materials	Max Temp (°F)	Min Temp. (°F)	Code of Contrstruction	Category	CRN
13010913-1	10-D16	13-16	13988	A	10	See Drawings	200	-20	ASME B31.3 2012 ED.	F	
13010913-2	12SHSNP4-M525	P4, P9	13994	A	12						
13010913-3	10-F12	10-12	14001	A	10						
13010913-4	J6-160	126-164	13996	A	6, 21, 54, 120, 120K, 400, 400K						
13010913-5	J6-680	680	13999	A	6, 100, 120						
13010913-6	J6-614	610 - 616	13987	A	6, 54, 100, 120, 400						
13010913-7	J6-274	254, 258-274	13984	A	6, 21, 40, 100, 120, 400						
13010913-8	H100-174	171-174	14000	A	100, 117, 120						
13010913-9	H117-706	700-706, 36-39	13990	A	100, 117, 120						
13010913-10	H100-376	354-376	13985	A	6, 21, 100, 120, 120K, 400						
13010913-11	H100-189	188-189, 488-489	13989	A	100, 117, 120						
13010913-12	TX200B14S1P	13, 14	13995	A	TX200						
13010913-13	J21K-232	232	13998	A	6, 21, 21K, 40, 100, 117						
13010913-14	H100-194	190-194, 490-494	13986	A	100, 117, 120						
13010913-15	J21K-S150B	S126B-S164B & 16021	13997	A	6, 21, 21K, 54, 120, 400						
13010913-16	J400-555	550-555, 570-572	13991	A	120, 400						
13010913-17	H100K-548	544-548	13993	A	100K, 117K, 120K, 400K						
13010913-18	H117-186	183-186, 483-486	14002	A	100, 117, 120						
13010913-19	J400K-457	455-457, 559	14004	A	120K, 400K						
13010913-20	H100K-543	540-543	13992	A	100K, 117K, 120K, 400K						
13010913-21	J120-454	440-454	14003	A	120, 400						

Dear Customer,

January 31, 2014

This letter is to inform you that the following models have been de-rated to meet Canadian design specifications for CRN registration. The remaining models published values meet Canadian design specifications.

Model Number	Canadian Maximum Design Pressure (psi)
P4, P9	10,100
160	160
189, 489	2,600
13, 14	9,800
194, 494	1,400
S147B, S150B, 16021	40
455 - 457, 559	125

Postal

180 Dexter Avenue
PO Box 9143
Watertown, MA
02472-9143
USA

Shipping

180 Dexter Avenue
Watertown, MA
02472-4200
USA

FAX

617-926-2568

Telephone

617-926-1000

Web Address

www.ueonline.com

Best regards,
Eric Moitoso

Certification Engineer

