


**UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS**

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON

PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES


NEWFOUNDLAND AND LABRADOR

|   |   |
|---|---|
| MANUFACTURERS NAME: <u>United Electric Controls</u>   |   |
| MANUFACTURERS ADDRESS: <u>180 Dexter Avenue, Watertown, MA, 02472</u>   |   |
| PLANT LOCATIONS:  |   |
| <p align="center"><b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b></p> <p>A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers<br/>                 B Flanges: all flanges<br/>                 C Valves: all line valves<br/>                 D Expansion joints, flexible connections, and hose assemblies: all types<br/>                 E Strainers, filters, separators, and steam traps<br/> <input checked="" type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters<br/>                 G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs<br/>                 H Pressure retaining components that do not fall into one of the above categories<br/>                 N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/>, (Meeting AECB or ASME requirements)</p> | <p align="center"><b>TITLE OF THE STANDARD OF CONSTRUCTION</b></p> <p align="center"><u>ASME B31.3</u></p>  |
| <p><b>SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT</b></p> <div style="text-align: center;">  <p><b>UNITED ELECTRIC<br/>CONTROLS</b><br/>LEADERS IN SAFETY, ALARM &amp; SHUTDOWN</p> </div>  | <p align="center"><b>TYPE OF CONSTRUCTION</b></p> <p>FORGED <input type="checkbox"/> WELDED <input checked="" type="checkbox"/> WROUGHT <input type="checkbox"/><br/>                 CAST <input type="checkbox"/> OTHER <input type="checkbox"/><br/>                 DESCRIBE OTHER:</p> |
| <p><b>LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:</b></p> <p><u>UE Pressure Product Bulletins, Hydrostatic/Proof Pressure Test Results, ISO 9001:2000 Quality System Certificate</u></p>  |   |

**DECLARATION:**  
 I, Eric F. Moitase (see note 3) employed by United Electric Controls and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by Det Norske Veritas as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: [Signature]  
 Declared before me at Watertown, MA  
 This 15<sup>th</sup> day of August AD 2012  
 Commissioner of Oaths or Notary Public: (sgn) [Signature]  
 (Affix Official seal to the right)


USE THIS SPACE FOR OFFICIAL SEAL



This space for Regulatory Authority use  
 This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: 0F12361.2  
 FID#: 961

Notes:  
 1. All fittings shall be registered in the name of the Manufacturer.  
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.  
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.  
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.



GOVERNMENT OF YUKON  
 BY: [Signature]  
 CRN: 0F12361.2  
 DATE: 10/10/12  
 BOILERS BRANCH



345 Carlingview Drive  
Toronto, Ontario  
CANADA M9W 6N9  
Tel.: 416.734.3300  
Fax.: 416.231.1626  
Toll Free: 1.877.682.8772  
[www.tssa.org](http://www.tssa.org)

March 29, 2018

SCOTT KAYHART  
UNITED ELECTRIC CONTROLS  
180 DEXTER AVE  
WATERTOWN MA 02472  
US

Service Request Type.: BPV-National ACI Central  
Service Request No.: 2230776  
Your Reference No.:  
Registered to.: UNITED ELECTRIC CONTROLS

Dear SCOTT KAYHART,

Please find enclosed the original response from PEI,NS,NB,NFLD,YK,NWT,NU, registered under the CRN No.: 0F16515.59870YTNADD1.

As all jurisdictional fees are handled by the Technical Standards and Safety Authority (TSSA), you do not pay any jurisdictions directly.

Should you have any questions or require further assistance, I will be happy to assist you. For general enquiries, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail [customerservices@tssa.org](mailto:customerservices@tssa.org). When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Tanya Francis  
Administrative Assistant\_ BPV Engineering  
Tel. : 416-734-3423  
Fax : 416-231-6183  
Email : [tfrancis@tssa.org](mailto:tfrancis@tssa.org)


**UNIFORM STATUTORY DECLARATION FORM FOR THE REGISTRATION OF FITTING DESIGNS**

NEW BRUNSWICK  
NUNAVUT

NOVA SCOTIA  
YUKON

PRINCE EDWARD ISLAND  
NORTHWEST TERRITORIES

NEWFOUNDLAND AND LABRADOR


|  |   |
|--|---|
| MANUFACTURERS NAME: <u>United Electric Controls</u>  |   |
| MANUFACTURERS ADDRESS: <u>180 Dexter Avenue, Watertown, MA 02472 USA</u>   |   |
| PLANT LOCATIONS: <u>Same as above</u>  |   |
| <b>CATEGORY OF FITTINGS TO BE REGISTERED. CIRCLE ONE CATEGORY ONLY</b>   |   |
| A Pipe fittings, including couplings, tees, elbows, Ys, plugs, unions, pipe caps, or reducers<br>B Flanges: all flanges<br>C Valves: all line valves<br>D Expansion joints, flexible connections, and hose assemblies: all types<br>E Strainers, filters, separators, and steam traps<br><input checked="" type="radio"/> F Measuring devices, including pressure gauges, level gauges, sight glasses, levels, or pressure transmitters<br>G Certified capacity-rated pressure relief devices acceptable as primary over pressure protection on boilers, pressure vessels, piping and fusible plugs<br>H Pressure retaining components that do not fall into one of the above categories<br>N Nuclear components: Class 1 <input type="checkbox"/> Class 2 <input type="checkbox"/> Class 3 <input type="checkbox"/> , (Meeting AECB or ASME requirements) | TITLE OF THE STANDARD OF CONSTRUCTION<br><u>ASME B31.3</u>  |
| SHOW MANUFACTURERS NAME, TRADEMARK, OR LOGO AS IT WILL APPEAR ON THE PRODUCT   |   |
|   | TYPE OF CONSTRUCTION<br>FORGED <input type="checkbox"/> WELDED <input checked="" type="checkbox"/> WROUGHT <input checked="" type="checkbox"/><br>CAST <input type="checkbox"/> OTHER <input type="checkbox"/><br>DESCRIBE OTHER: |
| LIST OF SUPPORTING DOCUMENTATION AND IDENTIFICATION OF THE ACTUAL ITEMS TO BE REGISTERED:  |   |
| Drawings: Refer to PVEscp-6706.1<br>Calculations: PVEcl-6706-0.0<br>Burst Report: 13010913   |   |

**DECLARATION:**

I Brenda Ripley (see note 2) employed by United Electric Controls and being the person having full authority and responsibility for the quality of the end product do solemnly declare that the information contained in this form is true and to the best of my knowledge represents the product for which registration is sought. The dimensions, materials of construction, pressure temperature ratings, and identification markings are in accordance with the herein named standards. I further declare that the manufacture of these fittings is regulated by a Quality Control Program which extends to each plant where fabrication occurs in whole or in part and has been verified by DNV GL for ISO 9001:2015 as being suitable for that purpose and I make this solemn declaration conscientiously believing it to be true, and knowing that it is of the same force and effect as if made under oath.

Signature of Declarer: Brenda Ripley  
 Declared before me at 180 Dexter Ave, Watertown, MA 02472  
 This 3rd day of January AD 2018  
 Commissioner of Oaths  
 or Notary Public: (sign) Brian Callman  
 (Affix Official seal to the right)


U S E T H E R E S A C P P O L G M A N F O  
 Notary Public  
 Commonwealth of Massachusetts  
 My Commission Expires  
 September 20, 2024



This space for Regulatory Authority use  
 This registration must be revalidated after ten (10) years from the date of acceptance.

CRN: OF16515.5 ADD1  
 FID#: 961

Notes:  
 1. All fittings shall be registered in the name of the Manufacturer.  
 2. Each category shall be supported with two Statutory Declaration forms and one copy of supporting documentation.  
 3. The declaration shall be made by the person having full authority and responsibility for the quality of the end product.  
 4. Quality control programs shall be resubmitted for validation at a maximum interval of five (5) years.





**File Name:** PVEscp-6706.1  
**Document Name:** Scope of Work  
**PVE Project:** PVE-6706  
**Revision:** 1  
**PVE Contact:** Patrick Fernandes  
**United Electric Contact:** Eric Moitoso

05-Dec-17

| Registration Information |                         |                     |             |          | Burst Test Results                 |              |               | CRN Info       |                        |          |     |
|--------------------------|-------------------------|---------------------|-------------|----------|------------------------------------|--------------|---------------|----------------|------------------------|----------|-----|
| Burst Sample No.         | Burst Test Series-Model | Applicable Models   | Drawing No. | Dwg Rev. | Compatible Series Numbers          | Materials    | Max Temp (°F) | Min Temp. (°F) | Code of Contrstruction | Category | CRN |
| 13010913-1               | 10-D16                  | 13-16               | 13988       | A        | 10                                 | See Drawings | 200           | -20            | ASME B31.3<br>2012 ED. | F        |     |
| 13010913-2               | 12SHSNP4-M525           | P4, P9              | 13994       | A        | 12                                 |              |               |                |                        |          |     |
| 13010913-3               | 10-F12                  | 10-12               | 14001       | A        | 10                                 |              |               |                |                        |          |     |
| 13010913-4               | J6-160                  | 126-164             | 13996       | A        | 6, 21, 54, 120, 120K,<br>400, 400K |              |               |                |                        |          |     |
| 13010913-5               | J6-680                  | 680                 | 13999       | A        | 6, 100, 120                        |              |               |                |                        |          |     |
| 13010913-6               | J6-614                  | 610 - 616           | 13987       | A        | 6, 54, 100, 120, 400               |              |               |                |                        |          |     |
| 13010913-7               | J6-274                  | 254, 258-274        | 13984       | A        | 6, 21, 40, 100, 120, 400           |              |               |                |                        |          |     |
| 13010913-8               | H100-174                | 171-174             | 14000       | A        | 100, 117, 120                      |              |               |                |                        |          |     |
| 13010913-9               | H117-706                | 700-706, 36-39      | 13990       | A        | 100, 117, 120                      |              |               |                |                        |          |     |
| 13010913-10              | H100-376                | 354-376             | 13985       | A        | 6, 21, 100, 120, 120K,<br>400      |              |               |                |                        |          |     |
| 13010913-11              | H100-189                | 188-189, 488-489    | 13989       | A        | 100, 117, 120                      |              |               |                |                        |          |     |
| 13010913-12              | TX200B14S1P             | 13, 14              | 13995       | A        | TX200                              |              |               |                |                        |          |     |
| 13010913-13              | J21K-232                | 232                 | 13998       | A        | 6, 21, 21K, 40, 100, 117           |              |               |                |                        |          |     |
| 13010913-14              | H100-194                | 190-194, 490-494    | 13986       | A        | 100, 117, 120                      |              |               |                |                        |          |     |
| 13010913-15              | J21K-S150B              | S126B-S164B & 16021 | 13997       | A        | 6, 21, 21K, 54, 120, 400           |              |               |                |                        |          |     |
| 13010913-16              | J400-555                | 550-555, 570-572    | 13991       | A        | 120, 400                           |              |               |                |                        |          |     |
| 13010913-17              | H100K-548               | 544-548             | 13993       | A        | 100K, 117K, 120K, 400K             |              |               |                |                        |          |     |
| 13010913-18              | H117-186                | 183-186, 483-486    | 14002       | A        | 100, 117, 120                      |              |               |                |                        |          |     |
| 13010913-19              | J400K-457               | 455-457, 559        | 14004       | A        | 120K, 400K                         |              |               |                |                        |          |     |
| 13010913-20              | H100K-543               | 540-543             | 13992       | A        | 100K, 117K, 120K, 400K             |              |               |                |                        |          |     |
| 13010913-21              | J120-454                | 440-454             | 14003       | A        | 120, 400                           |              |               |                |                        |          |     |

Dear Customer,

January 31, 2014

**Postal**

180 Dexter Avenue  
PO Box 9143  
Watertown, MA  
02472-9143  
USA

**Shipping**

180 Dexter Avenue  
Watertown, MA  
02472-4200  
USA

**FAX**

617-926-2568

**Telephone**

617-926-1000

**Web Address**

[www.ueonline.com](http://www.ueonline.com)

This letter is to inform you that the following models have been de-rated to meet Canadian design specifications for CRN registration. The remaining models published values meet Canadian design specifications.

| <b>Model Number</b> | <b>Canadian Maximum Design Pressure (psi)</b> |
|---------------------|---|
| P4, P9              | 10,100  |
| 160                 | 160   |
| 189, 489            | 2,600   |
| 13, 14              | 9,800   |
| 194, 494            | 1,400   |
| S147B, S150B, 16021 | 40  |
| 455 - 457, 559      | 125   |

Best regards,  
Eric Moitoso

Certification Engineer

